

RHENOCK FIRE STATION
PAKYONG DISTRICT – 737133
{27.176622°N 88.6432°E}
Ph No. 03592 - 253844



No: 14/POL/RFS/24

Dated: 16 / 03 / 20 24

NO OBJECTION CERTIFICATE

This is to certify that Green Wood Academy
Located at Rungdung, Rhenock, E. Sikkim has:


1. Buildings of RCC construction of bricks/stone masonry walls with GCI Sheets (non-combustible roofing's).
2. Provision for evacuation and egress system.
3. Provision for open spaces near the school buildings.
4. Installation of first fire fighting equipments in all blocks. (5)
5. Conduct Fire & Evacuation Drills and learnt to operate first aid fire fighting equipments in emergencies by all teachers and students.

Note: Valid for one year from the date of issue.

B. R. No: 2324 N- 11007- 9466 Date: 15 / 03 / 20 24

To,

The Director
Green Wood Academy
Rungdung, Rhenock,


Officer In-Charge
Rhenock Fire Station
Pakyong District
OFFICER IN-CHARGE
Rhenock Fire Station
Pakyong District Sikkim

Copy to:-

1. Director, Fire & Emergency Service, Gangtok – for kind information please.
2. Record File.